

CERTIFICATE

Applicant: Principal

School Name : MahaPragya Vidhya Niketan

Address : At- Koba Patiya, Dist- Gandhinagar.

This No Objection Certificate is given to **Principal** for period of **Dt.1/3/2023 to 28/2/2024** for school of "**MahaPragya Vidhya Niketan**" under condition listed below. The party has to abide by the rules of District Magistrate/ CPC Rule-21 sub Rule (1),(2),(3) and Rule-22 Sub Rule (1),(2),(3) This NOC is valid for one year from date of issue.

A 17/3/23
**Chief District Health Officer,
Gandhinagar.**

Desp. No/ Health/Certify/ 4314 /2023.
Health Department, District Panchayat
Gandhinagar.
Dt.17 /03/23

To,
**Principal,
MahaPragya Vidhya Niketan
At- Koba Patiya, Dist- Gandhinagar.**



CTC
**PRINCIPAL
MAHA PRAGYA VIDHYA NIKETAN
PREKSHA VISHWA BHARTI
KOBAPATIA
GANDHINAGAR-382426**



GUJARAT WATER SUPPLY & SEWERAGE BOARD
DISTRICT LABORATORY GANDHINAGAR
 Ground Floor, GJTI, G-Road, Sec-15, Gandhinagar



Test Report

Name & Address of Customer:-

Mahapragya Vidya Niketan

Customer Reference No.:-

Nr. Koba Circle

Sample Submitted by :Sender

Gandhinagar

Date of Sample Receipt :07-Mar-2023

Analysis Starting Date :09-Mar-2023

Analysis Completion Date :09-Mar-2023

Dicipline:Chemical Testing,Group:Drinking Water

ULR - TC1009022000004034F

Test Report No.: 2172/2022-23

Date of Issue : 13-Mar-2023

Sample ID : 2172

Mode of Sample: Satisfactory

Main Source :Ground Water

Source :R.O. Water

Location :Ground Floor, R.O.

Village :Koba

Habitation :Koba

Taluka :Gandhinagar

District :Gandhinagar

Latitude :-

Longitude :-

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water


Sr.No.	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (23 rd Ed.2017), Method: 2120 C	< 2
2	Odour	-	IS : 3025 (Part 5) - 2018	Agreeable
3	Turbidity	NTU	APHA (23 rd Ed.2017), Method: 2130 B	0.35
4	pH at 25 ^o C	-	APHA (23 rd Ed.2017) Method: 4500 H ⁺ B	8.41
5	Conductivity at 25 ^o C	µS/cm	APHA (23 rd Ed.2017) Method: 2510 B	103
6	Total Dissolved Solids	mg/l	APHA (23 rd Ed.2017) Method: 2540 C	80
7	Total Hardness(as CaCO ₃)	mg/l	APHA (23 rd Ed.2017) Method: 2340 C	56
8	Calcium (as Ca ⁺²)	mg/l	APHA (23 rd Ed.2017) Method: 3500 Ca ⁺² B	10
9	Magnesium (as Mg ⁺²)	mg/l	APHA (23 rd Ed.2017) Method: 3500-Mg ⁺² B	8
10	Chloride (as Cl ⁻)	mg/l	APHA (23 rd Ed.2017) Method: 4500-Cl ⁻ B	12
11	Sulphate (as SO ₄ ⁻²)	mg/l	APHA (23 rd Ed.2017) Method: 4500-SO ₄ ⁻² E	2
12	Nitrate (as NO ₃ ⁻)	mg/l	APHA (23 rd Ed.2017) Method: 4500-NO ₃ ⁻ B	3.14
13	Fluoride (as F ⁻)	mg/l	APHA (23 rd Ed.2017) Method: 4500-F ⁻ C	0.09
14	Total Alkalinity(as CaCO ₃)	mg/l	APHA (23 rd Ed.2017) Method: 2320 B	32

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.

Check By:

R. Vaidya
 Riddhi Vaidya
 (Dy. TMg)



Issued By:

Khyati Nayak
 (Quality Manager)
 Authorized Signatory

CTC
 PRINCIPAL
 MAHAPRAGYA VIDYA NIKETAN
 PREKSHA VISHWA BHARTI
 KOBAPATIA
 GANDHINAGAR-382426